Typical Specifications

Model: HLC-B

Description: Fan shall be a hooded, low profile, roof mounted, belt driven, downblast

centrifugal exhaust ventilator.

Certifications: Fan shall be manufactured at an ISO 9001 certified facility. Fan shall be listed by

Underwriters Laboratories (UL 705) and UL listed for Canada (cUL 705). Fan shall bear the AMCA certified ratings seal for sound and air performance.

Shall bear the Alvion Certified Fathigs Sear for Sound and all performance.

Construction: The fan shall be of bolted and welded construction utilizing corrosion resistant

fasteners. The fan shall be enclosed with a minimum .064 aluminum hood bolted to the fan housing. The hood shall be removable to allow unobstructed access to the motor and power assembly. The aluminum base shall have continuously welded curb cap corners for maximum leak protection. Bearings and drives shall be mounted on a minimum 12 gauge steel power assembly, isolated from the unit structure with rubber vibration isolators. Unit shall bear an engraved aluminum nameplate. Nameplate shall indicate design CFM, static pressure, and

maximum fan RPM. Unit shall be shipped in ISTA certified transit tested

packaging.

Wheel: Wheel shall be centrifugal backward inclined, constructed of 100% aluminum,

including a precision machined cast aluminum hub. Wheel inlet shall overlap an aerodynamic aluminum inlet cone to provide maximum performance and efficiency. Wheel shall be balanced in accordance with AMCA Standard 204-05,

Balance Quality and Vibration Levels for Fans.

Motor: Motor shall be NEMA design B with class B insulation rated for continuous duty

and furnished at the specified voltage, phase and enclosure.

Bearings: Bearings shall be designed and individually tested specifically for use in air

handling applications. Construction shall be heavy duty regreasable ball type in a cast iron housing selected for a minimum L50 life in excess of 200,000 hours at

maximum cataloged operating speed.

Belts & Drives: Belts shall be oil and heat resistant, static conducting. Drives shall be precision

machined cast iron type, keyed and securely attached to the wheel and motor shafts. Drives shall be sized for 150% of the installed motor horsepower. The

variable pitch motor drive must be factory set to the specified fan RPM.

Product: Fan shall be model HLC-B as manufactured by

Loren Cook Company of Springfield, Missouri.