

Typical Specifications

Model: CPA-A

Description: Fan shall be a single width, single inlet, backward inclined airfoil, direct driven centrifugal utility vent set.

Certifications: Fan shall be manufactured at an ISO 9001 certified facility. Fan shall be listed by Underwriters Laboratories (UL/cUL 705) for US and Canada. For restaurant applications, fan shall be listed as power ventilator by Underwriters Laboratories for US and Canada. Fan shall bear the AMCA certified ratings seal for air performance.

Construction: The fan shall be of bolted and welded construction utilizing corrosion resistant fasteners. The scroll wrapper shall be minimum 0.100" aluminum and the scroll side panels shall be minimum 0.100" aluminum. The entire fan housing shall have continuously welded seams for leakproof operation. A performance cut-off shall be furnished to prevent the recirculation of air in the fan housing. The fan housing shall be field rotatable to any one of seven discharge positions and shall have a minimum 1-1/2 inch outlet discharge flange. Motor support shall be minimum 10 gauge welded steel. Lifting lugs shall be provided for ease of installation. Unit shall bear an engraved aluminum nameplate. Nameplate shall indicate design CFM, static pressure, and maximum fan RPM. Unit shall be shipped in ISTA certified transit tested packaging.

Coating: Steel fan components shall be Lorenized™ with an electrostatically applied, baked polyester powder coating. Each component shall be subject to a five stage environmentally friendly wash system, followed by a minimum 2 mil thick baked powder finish. Paint must exceed 1,000 hour salt spray under ASTM B117 test method.

Wheel: Wheel shall be aluminum centrifugal airfoil blade type. Blades shall be continuously welded to the backplate and deep spun inlet shroud. Wheel hub shall be keyed and securely attached to the motor shaft. Wheel inlet shall overlap an aerodynamic aluminum inlet cone to provide maximum performance and efficiency. Wheel shall be balanced in accordance with AMCA Standard 204-05, *Balance Quality and Vibration Levels for Fans*.

Motor (CPA-A): Motor shall be NEMA design B with class B insulation rated for continuous duty and furnished at the specified voltage, phase and enclosure.

Motor (CPA-A VF): Motor shall be an electronically commutated motor rated for continuous duty and furnished either with internally mounted potentiometer speed controller or with leads for connection to 0-10 VDC external controller.

Product: Fan shall be model CPA-A as manufactured by Loren Cook Company of Springfield, Missouri.

9/22/21