

Typical Specifications

- Model:** TLCH-B
- Description:** Fan shall be a tiered aluminum, low profile, roof mounted, belt driven, centrifugal exhaust ventilator utilizing hurricane resistant louvers.
- Certifications:** Fan shall be manufactured at an ISO 9001 certified facility. Fan shall be listed by Underwriters Laboratories (UL 705) and UL Listed for Canada (cUL 705). Louvers utilized in penthouse construction shall have passed Florida/Miami-Dade County Hurricane Test Criteria: TAS-201: Large Missile Impact Test, TAS-202: Uniform Static Air Pressure Test, and TAS-203 Cyclic Wind Pressure Test. (Notice of Acceptance Number 03-0701.05)
- Construction:** The fan shall be of bolted and welded construction utilizing corrosion resistant fasteners. The fan shall be enclosed in a tiered extruded aluminum penthouse constructed of Miami-Dade County Approved ELF6375DXD drainable stationary louvers as manufactured by Ruskin. Hurricane design boxed corner louver penthouse is also known as Ruskin model PHB6375DXD. Bearings, drives and motor shall be mounted on a minimum 12 gauge steel power assembly, isolated from the unit structure with rubber vibration isolators. Unit shall bear an engraved aluminum nameplate. Nameplate shall indicate design CFM, static pressure, and maximum fan RPM. Unit shall be shipped in ISTA Certified Transit Tested Packaging.
- Wheel:** Wheel shall be centrifugal backward inclined, constructed of 100% aluminum, including a precision machined cast aluminum hub. Wheel inlet shall overlap an aerodynamic aluminum inlet cone to provide maximum performance and efficiency. Wheel shall be balanced in accordance with AMCA Standard 204-05, Balance Quality and Vibration Levels for Fans.
- Motor:** Motor shall be NEMA design B with class B insulation rated for continuous duty and furnished at the specified voltage, phase and enclosure.
- Bearings:** Bearings shall be designed and individually tested specifically for use in air handling applications. Construction shall be heavy duty regreasable ball type in a cast iron housing selected for a minimum L50 life in excess of 200,000 hours at maximum cataloged operating speed.
- Belts & Drives:** Belts shall be oil and heat resistant, static conducting. Drives shall be precision machined cast iron type, keyed and securely attached to the wheel and motor shafts. Drives shall be sized for 150% of the installed motor horsepower. The variable pitch motor drive must be factory set to the specified fan RPM.
- Product:** Fan shall be TLCH-B as manufactured by Loren Cook Company of Springfield, Missouri.