

Typical Specifications

Model: TCNH-D

Description: Fan shall be duct mounted, direct drive tubular centrifugal inline.

Certifications: Fan shall be manufactured at an ISO 9001 certified facility. Fan shall be listed by Underwriters Laboratories (UL/cUL 705) for US and Canada. Fan shall bear the AMCA certified ratings seal for sound and air performance.

Construction: The fan shall be of welded and bolted construction utilizing corrosion resistant fasteners. Housing shall be minimum 12 gauge Lorenized™ steel with integral inlet and outlet flanges. The fan housing shall include an access door that provides unrestricted access to the motor and wheel. Mounting brackets shall be welded to the outer housing to accommodate universal mounting feet for vertical or horizontal installation. Unit shall bear an engraved aluminum nameplate. Nameplate shall indicate design CFM and static pressure. Unit shall be shipped in ISTA certified transit tested packaging.

Wheel: Wheel shall be steel centrifugal backward inclined, non-overloading flat blade type. Blades shall be continuously welded to the backplate and deep spun inlet shroud. Wheel hub shall be keyed and securely attached to the fan shaft. Wheel inlet shall overlap an aerodynamically efficient aluminum inlet cone to provide maximum performance and efficiency. Wheel shall be balanced in accordance with AMCA Standard 204-05, *Balance Quality and Vibration Levels for Fans*.

Coating: Steel fan components shall be Lorenized™ with an electrostatically applied, baked polyester powder coating. Each component shall be subject to a five stage environmentally friendly wash system, followed by a minimum 2 mil thick baked powder finish. Paint must exceed 1,000 hour salt spray under ASTM B117 test method.

Motor: Motor shall be heavy duty type TEFC motor with permanently lubricated sealed ball bearings and furnished at the specified voltage and phase.

Product: Fan shall be model TCNH-D as manufactured by Loren Cook Company of Springfield, Missouri.